

Sample No. **AW04667**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C4694FD 0666FL

Collection Point : CAFETERIA WATER COOLER 2

ID of Source : PUBLIC

Agency : Private, Westchester

Collected By : B. TANNER

Collection Date : 03/06/2020 AT 10:00:00AM

Submitted On : 03/06/2020 AT 1:28:00PM

PWS No. :

Type Descriptor : Source ID : 000

pH :

Free Cl2 :

Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

add'l Report To :

Comment : BTANNER@AMANICHARTER.ORG

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	< LOQ		ug/L	1.0	03/12/2020	MO

*The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.
A result of <LOQ indicates that no lead was detected in the sample above the current Limit of Quantitation which is 1ug/L.*

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04668**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C4894FL 4773FD

Collection Point : KITCHEN SINK

Collected By : B. TANNER
Collection Date : 03/06/2020 AT 10:00:00AM
Submitted On : 03/06/2020 AT 1:28:00PM

ID of Source : PUBLIC

Agency : Private, Westchester

PWS No. :
Type Descriptor : Source ID : 000
pH :

Free Cl2 : Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

add'l Report To :

Comment :BTANNER@AMANICHARTER.ORG

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	3.1		ug/L	1.0	03/12/2020	MO

The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04669**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C4695FD 4698FL

Collection Point : GYM

ID of Source : PUBLIC

Agency : Private, Westchester

Collected By : B. TANNER

Collection Date : 03/06/2020 AT 10:00:00AM

Submitted On : 03/06/2020 AT 1:28:00PM

PWS No. :

Type Descriptor : Source ID : 000

pH :

Free Cl2 : Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

add'l Report To :

Comment : BTANNER@AMANICHARTER.ORG

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	< LOQ		ug/L	1.0	03/12/2020	MO

The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.

A result of <LOQ indicates that no lead was detected in the sample above the current Limit of Quantitation which is 1ug/L.

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04670**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C4733FD 0027FL

Collection Point : 2ND FL WATER FOUNTAIN

Collected By : B. TANNER
Collection Date : 03/06/2020 AT 10:00:00AM
Submitted On : 03/06/2020 AT 1:28:00PM

ID of Source : PUBLIC

Agency : Private, Westchester

PWS No. :
Type Descriptor : Source ID : 000

pH :
Free Cl2 : Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

add'l Report To :

Comment :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	< LOQ		ug/L	1.0	03/12/2020	MO

The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.

A result of <LOQ indicates that no lead was detected in the sample above the current Limit of Quantitation which is 1ug/L.

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04671**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C3622FL 4030FD

Collection Point : STAFF WATER COOLER

ID of Source : PUBLIC

Agency : Private, Westchester

Collected By : B. TANNER
Collection Date : 03/06/2020 AT 10:00:00AM
Submitted On : 03/06/2020 AT 1:28:00PM

PWS No. :

Type Descriptor : Source ID : 000

pH :

Free Cl2 : Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

add'l Report To :

Comment :BTANNER@AMANICHARTER.ORG

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	< LOQ		ug/L	1.0	03/12/2020	MO

*The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.
A result of <LOQ indicates that no lead was detected in the sample above the current Limit of Quantitation which is 1ug/L.*

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04672**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Collection Point : CAFETERIA WATER COOLER 1

ID of Source : PUBLIC

Agency : Private, Westchester

Received By : VA
Bottle No : C0482FL 4723FD

Collected By : B. TANNER
Collection Date : 03/06/2020 AT 10:00:00AM
Submitted On : 03/06/2020 AT 1:28:00PM

PWS No. :
Type Descriptor : **Source ID :** 000
pH :
Free Cl2 : **Residual Cl2 :**
Sample chilled on arrival ? : NA
Sample Type : POT_DW
Comment : BTANNER@AMANICHARTER.ORG

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	< LOQ		ug/L	1.0	03/12/2020	MO

*The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.
A result of <LOQ indicates that no lead was detected in the sample above the current Limit of Quantitation which is 1ug/L.*

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By Robert Hilbrandt

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04673**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C0476FD 2160FL

Collection Point : 3RD FL WATER FOUNTAIN

ID of Source : PUBLIC

Agency : Private, Westchester

Collected By : B. TANNER
Collection Date : 03/06/2020 AT 10:00:00AM
Submitted On : 03/06/2020 AT 1:28:00PM

PWS No. :
Type Descriptor : Source ID : 000

pH :
Free Cl2 : Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

Comment :BTANNER@AMANICHARTER.ORG

add'l Report To :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	2.2		ug/L	1.0	03/12/2020	MO
-----------	---------------------------------	-----	--	------	-----	------------	----

The results for the Lead Flush sample and the Lead First Draw sample appeared to be reversed. The Laboratory rechecked sample bottle identification and the analysis sequence and confirmed the reported results. The reported results meet Lead in Drinking Water requirements; we apologize for any confusion this may have caused. RWHJr

EPA 200.8	Lead	1.6		ug/L	1.0	03/12/2020	MO
-----------	------	-----	--	------	-----	------------	----

The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04674**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C0356FD 0033FL

Collection Point : GROUND FLOOR FOUNTAIN

Collected By : B. TANNER
Collection Date : 03/06/2020 AT 10:00:00AM
Submitted On : 03/06/2020 AT 1:28:00PM

ID of Source : PUBLIC

Agency : Private, Westchester

PWS No. :
Type Descriptor : Source ID : 000

pH :
Free Cl2 : Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

add'l Report To :

Comment :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	< LOQ		ug/L	1.0	03/12/2020	MO

*The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.
A result of <LOQ indicates that no lead was detected in the sample above the current Limit of Quantitation which is 1ug/L.*

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04675**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C4784FD 3591FL

Collection Point : 1ST FL WATER FOUNTAIN

Collected By : B. TANNER
Collection Date : 03/06/2020 AT 10:00:00AM
Submitted On : 03/06/2020 AT 1:28:00PM

ID of Source : PUBLIC

Agency : Private, Westchester

PWS No. :
Type Descriptor : Source ID : 000

pH :

Free Cl2 : Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

add'l Report To :

Comment :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
Inorganics							
EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	< LOQ		ug/L	1.0	03/12/2020	MO

*The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.
A result of <LOQ indicates that no lead was detected in the sample above the current Limit of Quantitation which is 1ug/L.*

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04676**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C0472FL 4887FD

Collection Point : NURSE OFFICE

ID of Source : PUBLIC

Agency : Private, Westchester

Collected By : B. TANNER
Collection Date : 03/06/2020 AT 10:00:00AM
Submitted On : 03/06/2020 AT 1:28:00PM

PWS No. :

Type Descriptor : Source ID : 000

pH :

Free Cl2 : Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

add'l Report To :

Comment :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	< LOQ		ug/L	1.0	03/12/2020	MO

*The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.
A result of <LOQ indicates that no lead was detected in the sample above the current Limit of Quantitation which is 1ug/L.*

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.

Sample No. **AW04677**

REPORT OF ANALYSIS

Westchester County Department of Labs and Research

10 Dana Road Valhalla, New York 10595

Sample Location : APCS
60 S. 3RD AVE
MOUNT VERNON, NY 10550

Received By : VA
Bottle No : C0475FD 4682FL

Collection Point : STAFF LOUNGE SINK

Collected By : B. TANNER
Collection Date : 03/06/2020 AT 10:00:00AM
Submitted On : 03/06/2020 AT 1:28:00PM

ID of Source : PUBLIC

Agency : Private, Westchester

PWS No. :
Type Descriptor : Source ID : 000
pH :

Free Cl2 : Residual Cl2 :

Sample chilled on arrival ? : NA

Sample Type : POT_DW

add'l Report To :

Comment :

Method	Test Description	Results	Qualifier	Units	DL/LOQ	Analyzed on	Validator
--------	------------------	---------	-----------	-------	--------	-------------	-----------

Inorganics

EPA 200.8	Lead - after flushing of faucet	< LOQ		ug/L	1.0	03/12/2020	MO
EPA 200.8	Lead	< LOQ		ug/L	1.0	03/12/2020	MO

*The Action level for Lead as set by NYSDOH is 15ug/L. If your result is greater than 15ug/L please contact your local health department.
A result of <LOQ indicates that no lead was detected in the sample above the current Limit of Quantitation which is 1ug/L.*

DL = Detection Limit

LOQ = Limit of Quantitation

J=value is an estimate

H = exceeds holding time

Approved By **Robert Hilbrandt**

QA Officer

Date Approved : 03/12/2020

Environmental Laboratories
NYS ELAP # 10108
(914) 231-1620

Report Number: 925

EMAIL 3/13/2020

Page 1 of 1

These analytical results relate only to the sample identified in this report.